

2010 Consumer Confidence Report

Water System Name: Hillsview Homes Report Date: June 29, 2011

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2010.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Ground Water

Name & location of source(s): Well 1, Well2, Westley, CA

Drinking Water Source Assessment information: An assessment for the drinking water sources for the Hillsview Homes water system was completed in January 2002. The sources are considered most vulnerable to the following activities: wastewater treatment plants, gas stations, airports (maintenance and fueling areas) and utility stations. A copy of the complete assessment is available at the Department of Health Services, Drinking Water Field Operation Branch, Stockton District Office, 31 E. Channel Street, Room 270, Stockton, CA 95202 or at the Housing Authority of the County of Stanislaus, 1701 Robertson Road, Modesto, CA 95351. You may request a copy of the summary be sent to you by contacting Joseph O. Spano, District Engineer, at (209) 948-7696 or Scott Fitzgerald at the Housing Authority of the County of Stanislaus at (209) 557-2078.

Time and place of regularly scheduled board meetings for public participation: 5:30 PM, 3rd Tuesday, Monthly at the Regular Housing Authority Commission Meeting, 1701 Robertson Road, Modesto, CA 95351

For more information, contact: Scott Fitzgerald Phone: (209) 557-2078

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	10	ND	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	10	.11	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	11/16/09	101.3	85.6-117	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	11/16/09	605	550-660	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Gross Alpha Particle Activity (pCi/L)	10/2/02	6.07	4.58-7.57	15	0	Erosion of natural deposits
Uranium (pCi/L)	10/2/02	1.41	1.38-1.44	20	.43	Erosion of natural deposits
Nitrate as NO ₃ (ppm)	11/16/10	21.9	21.1-22.6	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Fluoride (ppm)	11/16/09	.115	0.11-0.12	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Radium 228 (pCi/L)	3/5/07 6/4/07 9/6/07 12/6/07	.192	.000-.520	2	0	Erosion of natural deposits
Selenium (ppb)	11/16/09	8.75	8.4-9.0	50	(50)	Discharge from petroleum, glass and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Arsenic (ppb)	11/16/09	1.05	0-2.11	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Haloacetic Acids (ppb)	09/07/10	ND	X	60	N/A	By product of drinking water chlorination
Total Trihalomethanes (ppb)	09/07/10	2.1	X	80	N/A	By product of drinking water chlorination
Chlorine (ppm)	Running Annual Average	1.17	.69-1.39	[4.0] as Cl ₂	[4.0] as Cl ₂	Drinking water disinfectant added for treatment
Turbidity (Units)	11/16/09	.4	.1-.7	5	N/A	Soil runoff.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (ppm)	11/16/09	1280*	1120-1440	1000	N/A	Runoff/leaching from natural deposits

Chloride (ppm)	11/16/09	304	214-394	500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	11/16/09	297	280-314	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Specific Conductance (microhms)	11/16/09	2190*	1830-2550	1600	N/A	Substances that form ions when in water; seawater influence

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron (ppm)	1/8/03	.538	.538	1 ppm	Some men who drink water containing boron in excess of the notification level over many years may experience reproductive effects, based on studies in dogs.
Chromium VI (ppb) (Hexavalent chromium)	5/8/02	2.5	2.5	N/A	N/A
Vanadium (ppb)	1/8/03	5.7	5.7	50 ppb	The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and/or flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the USEPA Safe Drinking Water Hotline (1-800-426-4791).

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a Violation of Any Treatment Technique or Monitoring and Reporting Requirement

Total Dissolved Solids were detected at levels that exceed the secondary MCL of 1000 mg/L. and Specific Conductance was found to exceed the secondary MCL of 1600 microhms. Secondary MCL's were set to protect you against unpleasant aesthetic effects such as color, taste and odor. The high Total Dissolved Solids levels are due to leaching of natural deposits. High Specific Conductance is caused by substances that form ions while in the water.

On November 1, 2010, the Hillsview Homes Water System issued a Boil Water Order due to a sewer overflow in close proximity to a water line break. Repairs were made to the system and comprehensive testing of the water was conducted to ensure the water was safe to drink. All of the testing showed no contamination of the water system and the Boil Water Order was rescinded on November 29, 2010.

For Water Systems Providing Ground Water as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0	XXXXXX	0	(0)	Human and animal fecal waste
Enterococci	0	XXXXXX	TT	n/a	Human and animal fecal waste
Coliphage	0	XXXXXX	TT	n/a	Human and animal fecal waste